

Date Prepared 05/2001
Prepared By Carla McGreevy
Revised 11/25/03, 9/17/08
By P. Watt

BMP Physical Plant #5

TITLE: Underground Tank Labeling

Regulatory Citation: 6 NYCRR Part 613.3 (b)

Applicability: All underground tanks must be labeled:

Purpose: To prevent improper filling of tanks.

Department Responsible: Exec Mgr Physical Plant/Stationary Engineers

Schedule: Tank fill ports must be inspected once per year to ensure that the tank's fill ports are properly labeled.

Procedures: All new tanks (installed after December 27, 1986) must bear a permanent stencil, label, or plate and have a second label at the fill port, which contains the following information:

- 1) Manufacturer's statement that, "This tank conforms with 6 NYCRR Part 614";
- 2) The standard of design that the tank was manufactured;
- 3) The petroleum products and percentages of volume of petroleum additives that may be stored permanently and compatibly within the tank or reference a list available from the manufacturer which identifies products compatible with all tank materials;
- 4) The year in which the tank was manufactured;
- 5) A unique identification number;
- 6) The dimensions, design and working capacity and model number of the tank;
and
- 7) The name of the manufacturer.

The symbol is based on the tank contents:

Diesel must be labeled with a yellow hexagon.

Gasoline must be labeled blue with a white cross.

Heating fuel must be labeled with a green hexagon.

Record keeping: Not Applicable.

Record Location: Not Applicable.

Contact: Director of Environmental, Health and Safety (629-7163)
Exec Mgr of Physical Plant (629-7427)
Assistant to Exec Mgr 629-7361

HVCC-BMP-PhysicalPlant#5-USTLabeling